

## **Addendum #2**

Date: 3-31-25

Project: Crenshaw County Sportsplex – Phase 3

Architect's Project #22-42

Number of Pages: 1

To: All Bidders

From: John H. Foshee

---

This addendum shall be considered part of the bid documents for the above-mentioned project. Where provisions of this following supplementary data differ from those of the original bid documents, this Addendum shall govern and take precedence. Bidders shall acknowledge this Addendum on the Form of Proposal.

- 1.) Fluid-Applied Vapor Permeable Membrane shall be equal to one of the following products:
  - a. Tremco - ExoAir 230
  - b. WR Meadows – Air-Shield LMP
  - c. Sika – Sikagard 535
  - d. Sto – VaporSeal
- 2.) Joint sealants to be manufacturer approved, in writing, for use with the selected fluid-applied vapor permeable membrane. Using the same manufacturer for the fluid-applied vapor permeable membrane and the joint sealants is preferable.
- 3.) No below grade waterproofing is required at the retaining walls. Care shall be used in installing the through-wall weep drains and the drainage layer behind the retaining walls, as specified in the structural drawings.

End of Addendum #2